

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4485-1332:101

Page 1 of 1

CATEGORY: Opening Protection (Firestopping)

LISTEE: Specified Technologies, 200 Evans Way #2, Somerville NJ 08876
Contact: James Stahl, Jr. (908) 526-8000 FAX (908) 231-8415

DESIGN: EZ-PATH Fire Rated Path Way firestop device. Device consists of a long galvanized steel tube with an intumescent material lining to capture grouped cables. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as a through-penetration firestop device for use in concrete and gypsumboard/stud wall assemblies up to 2 hour rating. Approved for UL System Designs Nos. W-J-3098, W-J-3099, W-L-3218, and W-L-3219. Refer to UL Fire Resistance Directory for complete installation and limitations.

03-18-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager